

WORK REPORT



'Take a Moment' RA completed? : Yes		Visit No. : 4000042679	Site No. : 10040955					
Site : County Bridge Club St Oswalds Road Leicester LE3 6RJ		Installer :						
Date : 18-Aug-2021	Commission : <input checked="" type="checkbox"/>	Service : <input type="checkbox"/>	Warranty request : <input type="checkbox"/>	Manufacturer visit : <input type="checkbox"/>				
Engineer : Richard Wilkes		Company : Baxi						
Card number : 4973158		Registration number : 500403						
1. Make : Potterton	Model : Sirius Three WH60	Ser no. : 211435011						
2. Make :	Model :	Ser no. :						
3. Make :	Model :	Ser no. :						
4. Make :	Model :	Ser no. :						
5. Make :	Model :	Ser no. :						
6. Make :	Model :	Ser no. :						
General information		Warranty general information						
Location on site	Plant Room	Correctly installed	Yes					
Gas type	Natural Gas	Maintenance issue						
Hours run / No. Starts	/	Water damage						
Total hours heating		Voltage damage						
Total hours DHW		Contaminated gas						
Work complete	Yes	Contaminated air						
Warranty heat exchanger information								
Flue manufacturer		Flue drain to Appl.	Metres					
Flue type		Flue drain clean						
Common flue		Appl. drain clean						
Length of flue	Metres	HX clean						
Flue material		Water sample	ref no.					
Flue corroded		Low water / flow						
Flue drain fitted		Filters clean						
Part fitted	Part number	Supplied / van	Primary Fault ?	Symptom	Component	Mode	Action	Return Barcode
Time and mileage				Travel time	Mileage	Arrival	Departure	Total site
Engineer name : Richard Wilkes				2	87	9:00	12:00	3
Report : Commissioned WH60 boiler. Increased fan speed on ignition from 2000 to 2300 revs to eliminate noise - tested - OK. Boiler left running and at temperature.								
Declaration of Gas Safety – I confirm that all of the above work described on this form has been satisfactorily completed in accordance with the current Gas Safety (installation & use) Regulations, standards and procedures. Signed Engineer :					Signed client :			
Print Engineer : Richard Wilkes					Print client :			



WORK REPORT



'Take a Moment' RA completed? : Yes		Visit No. : 4000042679	Site No. : 10040955
Site : County Bridge Club St Oswalds Road Leicester LE3 6RJ		Installer :	
Date : 18-Aug-2021	Commission : <input checked="" type="checkbox"/>	Service : <input type="checkbox"/>	Warranty request : <input type="checkbox"/>
Engineer : Richard Wilkes		Manufacturer visit : <input type="checkbox"/>	
Card number : 4973158		Company : Baxi	
		Registration number : 500403	

